

Technical Info

## **Declaration of Conformity**

Danfoss Compressors hereby declares that the following types of fan-cooled condensing units:

F, T, N, S, P, B, G (114G, 114H, 114U, 114E, 114F, 114X) in the versions N0 to N2,T0 to T2, A00 to A04

are in conformity with the Low Voltage Directive 73/23 as amended by Directive EEC 93/68, relating to electrical equipment designed for use within certain voltage limits.

## Applied norms:

Component	Norm
Compressor F, T, N, S, P, G	EN 60335-2-34
Compressor B	EN 50081-1 and EN 50082-1
	/Declaration of Conformity for the Compressor
Pressure Switch (KP)	EN 60730-2-9
	/Declaration of Conformity for the KP Pressure Controls
Refrigerant Receiver 118U0514, 0515, 0516	Pressure Equipment Directive 97/23/EC
Fan Motor (220-240V/50Hz)	EN 60335-2-80

A. Gernemann

Title: System & Assemblies Engineering Manager

Date: 15<sup>th</sup> of November, 2006

Danfoss can accept no responsibility for possible errors in catalogues, brochures and other printed material. Danfoss reserves the right to alter its products without notice. This also applies to products already on order provided that such alterations can be made without subsequential changes being necessary in specifications already agreed.

All trademarks in this material are property of the respective companies. Danfoss and the Danfoss logotype are trademarks of Danfoss A/S. All rights reserved.

Danfoss Compressors GmbH System & Assemblies

Mads-Clausen-Str. 7 D-24939 Flensburg / Germany compressors.danfoss.com