DECLARATION OF CONFORMITY

The Pressure Equipment Directive 97/23/EC



Name and Address of Manufacturer's Representative within the European Community

Danfoss Industrial Refrigeration A/S Stormosevej 10 PO Box 60 DK-8361 Hasselager Denmark

Description of Pressure Equipment

High pressure float valve

Type: HFI DN100 and DN150

Nominal bore	DN 100 and 150 mm (4 in. and 6 in.)	
Classified for	Fluid Group I (all refrigerants (toxic, nontoxic, flammable and nonflammable)). For further details / restrictions - see Installation Instruction.	
Temperature range and maximum allowable working pressure	All	Type 1: Ps 28 bar at -50°C/+80°C (-58°F/+176°F)

Conformity and Assessment Procedure Followed

Category	III
Module	B1+D
Certificate ID	07 202 0511 Z 0094/1/H (B1 = 0124 P 0201/1/0)
Nominal bore	DN 100 and DN 150 mm (4 in. And 6 in.)

Name and Address of the Notified Body, which carried out the Inspection

TÜV-Nord e.V.

Grosse Bahnstrasse 31

(0045)22525 Hamburg, Germany

Name and Address of the Notified Body monitoring the Manufacturer's Quality Assurance System

CE

TÜV-Nord e.V.

Grosse Bahnstrasse 31 22525 Hamburg, Germany

References of Harmonized Standards used

References of other Technical Standards and Specifications used

prEN 10028-3 DIN 3840 DIN 17173 AD-Merkblätter

Authorised Person for the Manufacturer's Representative within the European Community

Morten Steen Hansen Name: Title: **Production Manager**

arteri Steen Hansen 05/02/2002 Signature: Date:

RR2BA102 No.: 148B9707 Rev. 0