

DECLARATION OF CONFORMITY
The Pressure Equipment Directive 97/23/EC



Name and Address of Manufacturer's Representative within the European Community

Danfoss Industrial Refrigeration A/S
Stormosevej 10
PO Box 60
DK-8361 Hasselager
Denmark

Description of Pressure Equipment

Refrigerant check valve

Type: **NRVA**

Nominal bore	DN32-65 mm (1¼ - 2½ in.)	
Classified for	Fluid Group I (all refrigerants (toxic, nontoxic, flammable and nonflammable)). For further details / restrictions - see Installation Instruction.	
Temperature range	NRVA	-50°C/+140°C (-58°F/+285°F)
Maximum allowable working pressure	NRVA	28 bar (406 psi) -50°C/+80°C (-58°F/+176°F) 26 bar (377 psi) +80°C/+120°C (+176°F/+248°F) 24 bar (348 psi) +120°C/+140°C (+248°F/+284°F)

Conformity and Assessment Procedure Followed

Category	II	
Module	D1	
Certificate ID	-	
Nominal bore	Standard applications	DN32-65 mm (1¼ - 1½ in.)

Name and Address of the Notified Body which carried out the Inspection

TÜV-Nord e.V.
Grosse Bahnstrasse 31
22525 Hamburg, Germany



Name and Address of the Notified Body monitoring the Manufacturer's Quality Assurance System

TÜV-Nord e.V.
Grosse Bahnstrasse 31
22525 Hamburg, Germany

References of Harmonised Standards used

EN 10028-3 EN 10213-3 EN 10222-4

References of other Technical Standards and Specifications used

prEN 12284 DIN 3158
AD-Merkblätter DIN 17173

Authorised Person for the Manufacturer's Representative within the European Community

Name: Morten Steen Hansen Title: Production Manager

Signature:

Date: 11/03/2002