

Follow us on:



www.pegleryorkshire.co.uk



Endex

CERTIFICATE OF CONFORMITY

The Pressure Equipment Directive 97/23/EC

Pegler Yorkshire Group Ltd

St Catherine's Ave,
Doncaster, South Yorkshire,
DN4 8DF, England.

Company no : 00401507

Telephone: +44 (0) 844 243 4400

Fax: +44 (0) 844 243 9870

Name and Address of Authorised Person for the Manufacture within the European Community:

Pegler Yorkshire Group Ltd, St Catherines Avenue, Doncaster DN4 8DF

Description of Pressure Equipment:

Endex Copper Fittings up to 54mm nominal diameter

Conformity Assessment Procedure followed:

All products within the above listed range are subject to Sound Engineering Practice (Article 3, paragraph 3) of the Pressure Equipment Directive (PED) – 97/23/EC, and as such are NOT required to be CE – marked

All fittings up to and including 54mm nominal diameter have been tested and found suitable for applications not exceeding 45 Bar at an operating temperature of 55C (ambient condition $\leq 32C$) 6mm to 54mm nominal 24bar maximum

Use for: Fluids of group 1

Applied Harmonised Standards

EN 378-2:2000

Applied Technical Specification:

MSS SP104-1995 ANSI B16 22-1995

Authorised person for the manufacture within the European Community

Name: Mr D. Rhodes

Title: Group Manager – Quality and Technical Services

Signature:

Phil Thornton – Quality Manager – Approvals
On behalf of Mr David Rhodes

Date: 13/10/2017

Follow us on:



www.peglyorkshire.co.uk



Pegler Yorkshire Group Ltd

St Catherine's Ave,
Doncaster, South Yorkshire,
DN4 8DF, England.

Company no : 00401507

Telephone: +44 (0) 844 243 4400

Fax: +44 (0) 844 243 9870