

Declaration of Conformity

Henry Technologies hereby declare that the Pressure Equipment listed below has been designed, manufactured and tested in accordance with the requirements of the Pressure Equipment Regulations 1999 (European Directive 97/23/EC)

Description of Pressure Equipment:

Description of Vessel / Assembly: Oil Level Regulators

Models covered:

(S.E.P.) S-9110, S-9120, S-9130, S-9191, S-9191A, S-9211, S-9211A ,S-9510, S-9530

Conformity and Assessment Procedure Followed

Category	SEP.
Module	N/A
Certificate	0041/D/1
PV.	< 50

Classified for	Group 2 Gases
Design pressure	31 bar
Maximum Op. Temp	+130° C
Minimum Op.Temp	-10° C

The following transposed European standards and other technical specifications have been used:


UL 207, EN 378

Notified Body:

The Notified Body which inspected the manufacturers quality assurance system:

Bureau Veritas
 Parklands
 Wilmslow Road
 Didsbury
 Manchester M20 2RE

Notified Body identification No. 0041

Signed:  Quality Assurance Manager Date: 3.5.05
 (Responsible Person - Name and actual Title)

