

Declaration of Conformity

Henry Technologies hereby declare that the Pressure Equipment listed below has been designed, manufactured and tested in accordance with the requirements of the Pressure Equipment Regulations 1999 (European Directive 97/23/EC)

Description of Pressure Equipment:

Description of Vessel / Assembly: Suction Line Accumulators

Models covered:

(Cat I) S-7057, S-7057HP, S-7061, S-7061HP.

(Cat II) S-7063, S-7063HP, S-7065, S-7065HP

Conformity and Assessment Procedure Followed

Category	Cat I	Cat II
Module	D1	D1
Certificate	0041/D/1	0041/D/1
PV.	50 - 200	200 - 1000

Classified for	Group 2 Gases
Design pressure	31 bar
Maximum Op. Temp	+ 80° C
Minimum Op. Temp	- 25° C

The following transposed European standards and other technical specifications have been used:


UL 207

Notified Body:

The Notified Body which inspected the manufacturers quality assurance system:

Plant Safety Ltd.
 Parklands
 Wilmslow Road
 Didsbury
 Manchester M20 2RE

Notified Body identification No. **0041**

Signed:  Quality Assurance Manager Date: 25.5.02
 (Responsible Person - Name and actual Title)

