

ROBA METALS B.V
 ZOMERDIJK 27-33
 3402 NL AA IJSSELSTEIN(NL)

INSPECTION CERTIFICATE

Type 3.1 acc. EN 10204

Certificate No : 1000511822

DATE: 18.03.2022

Delivery No : 0085250306

Customer	ROBA METALS B.V		
Cust's Ref No	PO-0034687-1/39th	Cust's Part No	19340
Our Order No	1200127888 / 60	Quantity	360,00 MTR
		Inspection Lot	020000753230

Designation	CuT m 041,275x2,70x5000 JJ ASO D R
-------------	------------------------------------

according to	EN 12735-1,R300 & tube properties to VdTÜV567 requirements
--------------	--

Material	CuFe2P
Chem. Anal.:	FE:2,1-2,6-P:0,015-0,150-PB<0,03-ZN:0,050-0,200-OTHERS TOTAL<0,200-CU:REM. OK

Characteristic	Unit of meas.	Specifications	Values	Sample No
ODmin	mm	>=41,165	41,260	2
ODmax	mm	<=41,385	41,300	2
ODav	mm	41,215 - 41,335	41,280	2
Smin	mm	>=2,538	2,670	2
Smax	mm	<=2,860	2,730	2
LENGTH	mm	>=5000	5006	2
STRAIGHTNS	mm/m	<=4,0	0,8	2
Rm	N/mm ²	>=300,0	331,0 - 337,2	2
Rp0,2	N/mm ²	140,0 - 250,0	144,0 - 151,6	2
Rp1	N/mm ²	>=160,0	177,4 - 182,9	2
A	%	>=30,0	34,6 - 35,9	2
C TOT. RES. IN.	mg/dm ²	<=0,38	0,08 - 0,14	2
ECT EN 1971	%	100	OK	-

DECLARATION OF COMFORMITY

The products detailed above, conform to the conditions and requirements of the purchaser and to the description, quantities and spec. stated. The Quality Assurance System applied to monitor their production, complies with the requirements of ISO 9001:2015, independently certified by TÜV HELLAS, with certification No 041070119.

Athens

21.03.2022

Q.C. INSPECTOR

Q.A. MANAGER



D. SKARMOUTSOS

FORM N3

ISSUE: C

REV: 2

DATE: DEC. 2017

e-mail: info@halcor.com
 website: www.halcor.com
 VAT number: EL094061318

Offices & Copper Tube Plant (Mailing Address)
 62nd km Athens-Lamia National Road,
 GR-32011 Inofita-Viotia, GREECE
 Tel.: +30 22620 48111, Fax: +30 22620 48911

Foundry
 60th km Athens-Lamia National Road,
 GR-32011 Inofita-Viotia, GREECE
 Tel.: +30 22620 53479, Fax: +30 22620 53925

Domestic Sales Dept
 252 Pireos str.
 GR-17778, Tavros, Athens, GREECE
 Tel.: +30 210 4898111, Fax: +30 210 4898397