

BEIJER REF SUPPORT B.V.  
 Westfields 1210  
 5688 HA Oirschot

**INSPECTION CERTIFICATE**  
**Type 3.1 acc. EN 10204**

**Certificate No : 1000510836**  
**Delivery No : 0085249519**

**DATE: 08.03.2022**

Customer	BEIJER REF SUPPORT B.V.		
Cust's Ref No	661022496	Cust's Part No	
Our Order No	1200128703 / 70	Quantity	560,00 MTR
		Inspection Lot	020000750635

Designation	CuT m 019,050x1,00x20000 JHHBO XB09-27 R		
according to	EN 12735-1 R220, PED 97/23 EC.		
Material	Cu-DHP		
Chem. Anal.:	CU>99,90-P:0,015-0,040	OK	

Characteristic	Unit of meas.	Specifications	Values	Sample No
ODav	mm	19,000 - 19,100	19,060 - 19,085	1
Smin	mm	>=0,850	0,880	1
Smax	mm	<=1,150	0,920	1
Sav	mm	<=0,915	0,900	1
LENGTH	mm	>=20000	20000	1
Rm	N/mm <sup>2</sup>	>=220,0	236,8	1
A50	%	>=40,0	52,3	1
C TOT. RES. IN.	mg/dm <sup>2</sup>	<=0,38	0,15	1
ECT EN 1971	%	100	OK	-

**DECLARATION OF COMFORMITY**

The products detailed above, conform to the conditions and requirements of the purchaser and to the description, quantities and spec. stated. The Quality Assurance System applied to monitor their production, complies with the requirements of ISO 9001:2015, independently certified by TÜV HELLAS, with certification No 041070119.

Athens

15.03.2022

Q.C. INSPECTOR

Q.A. MANAGER



D. SKARMOUTSOS

FORM N3

ISSUE: C

REV: 2

DATE: DEC. 2017

e-mail: info@halcor.com  
 website: www.halcor.com  
 VAT number: EL094061318

**Offices & Copper Tube Plant (Mailing Address)**  
 62<sup>nd</sup> km Athens-Lamia National Road,  
 GR-32011 Inofita-Viotia, GREECE  
 Tel.: +30 22620 48111, Fax: +30 22620 48911

**Foundry**  
 60<sup>th</sup> km Athens-Lamia National Road,  
 GR-32011 Inofita-Viotia, GREECE  
 Tel.: +30 22620 53479, Fax: +30 22620 53925

**Domestic Sales Dept**  
 252 Pireos str.  
 GR-17778, Tavros, Athens, GREECE  
 Tel.: +30 210 4898111, Fax: +30 210 4898397