



GROUP LIMITED

Telephone: (+44) (0)121 708 1123
Facsimile: (+44)(0)121 707 7793
Business to business www.leslie.co.uk
e-mail @leslie.co.uk


198 - 202 Waterloo Road, Yardley,
Birmingham, B25 8LD, England


European Pressure Directive

Certificate of Conformity for Gill Refrigeration Components.

All refrigeration valves and pipe line fittings produced under the "Gill" brand name, for use in both high and low pressure refrigeration systems, have been type tested for a working pressure of 30 Bar at a working temperature of 55 Degrees Celcius.

As part of this testing process it was established that all fittings will sustain a pressure without bursting of 65 Bar.


G. E. Williams
Technical Director


P Twining
Quality manager

8 June 2001.